

ADDENDUM NO. 3

**CITY OF HIALEAH
72 UNIT ELDERLY HOUSING
275 PALM AVE.
HIALEAH, FLORIDA**

DECEMBER 20, 2012

TO ALL CONCERNED

The original Contract Documents, for the Project entitled **CITY OF HIALEAH – 72 Unit Elderly Housing, RAILINGS AND MISCELLANEOUS METALS BID NO. 2012/13-3230-00-023** is hereby amended as noted in this **Addendum No. 3**.

This **Addendum No. 3** consists of **1** Typed Pages, **0** Sketches, **0** Attachments and **0** Drawings. All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue:  Date: December 20, 2012
Luis Azan - Project Manager

ACKNOWLEDGEMENT

Receipt of this **Addendum No. 3** shall be acknowledged in the space provided on the **ADDENDUM RECEIPT FORM (ARF)** (copy attached) now a part of the Contract Documents faxed immediately to City of Hialeah @ (305) 687-2642, and submitted with sealed bids.

IN THE CONTRACT DOCUMENTS:

Response to RFI from Marrero Group dated December 19, 2012:

Please provide the following details for the 72 Unit project involving Iron Work:

- 1) What is the metal thickness of the decorative screens on the balconies?

The thickness of the metal screens is to be a minimum 1/8"

RAILINGS & MISCELLANEOUS METALS-BID #2012/13-3230-00-023

**PAGE 1 OF 1
END OF ADDENDUM NO. 3**